

Consumer Notice: Drinking Water Lead Sample Results

Attention Consumer

Sand Creek High School– WSSN: 2019346

The above listed facility is classified as a public water system; therefore, we are responsible for providing you with drinking water that meets state and federal standards. The **attached table** provides information on the location, date, and water sample result(s) of lead testing at: **Sand Creek High School**

All lead samples will be reviewed by the Local Health Department to determine the 90th percentile value and compliance with the lead regulations.

What Does This Mean?

Under the authority of the Safe Drinking Water Act, 1976 PA 39, as amended, the U.S. Environmental Protection Agency (U.S. EPA) set the action level for lead in drinking water at 0.015 mg/L. This means water supply systems must ensure that water from taps used for human consumption does not exceed this level in at least 90 percent of the sites samples (90th percentile value). The action level is *the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow*. If water from the tap does exceed this limit, then the facility must take certain steps to correct the problem. Because lead may pose a serious health risk, the U.S. EPA set a Maximum Contaminant Level Goal (MCLG) of zero for lead. The MCLG is *the level of contaminant in drinking water below which there is no known or expected risk to health*. MCLG's have a margin of safety.

What Are The Health Effects of Lead?

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development.

To Reduce Exposure to Lead in Drinking Water:

- 1) Establish a flushing program, run water until it becomes cold.
- 2) Use only cold water for cooking or preparing baby formula.
- 3) Boiling water will not reduce lead levels.

For information on reducing lead exposure and the health effects of lead, visit the U.S. EPA's Website at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD(5323), or contact your health care provider. If you have questions please contact the water supply representative at 517-284-1524
(Phone Number/Email)

I certify this public water supply has provided the consumer notice of lead drinking water results through public posting approved by the Michigan Department of Environmental Quality (DEQ), within 30 days of knowing the result. This notice includes required content.

Alex McManis
Signature

System operator
Title

12/13/13
Date of Public Posting

Reminder to water supplier: A completed and signed copy of this consumer notice must be returned to the Michigan Department of Environmental Quality, as per cover letter guidance no later than 3 months following the receipt of lead sample results.

Consumer Notice: Drinking Water Lead Results

(Safe Drinking Water Act, 1976 PA 399, as amended)

The table below lists the most recent lead drinking water quality sample results. Lead samples are collected where cold water is typically drawn for consumption such as kitchen sinks, break room faucets, or drinking fountains. Each facility has an established sample siting plan to identify approved sample points, in addition to a predetermined monitoring frequency.

Water System Name : Sand Creek High School

Wssn : 2019346

<u>Sample Number</u>	<u>Sample Location</u>	<u>Sample Date</u>	<u>Results *</u> <small>milligrams / liter</small>	<u>Comment</u>
<small>Samples related to Source # 001</small>				
LE99668	KITCHEN	10/30/2013	0	
LE99669	LOUNGE	10/30/2013	0	
LE99671	WHEELER	10/30/2013	0	
LE99672	ROOM 101	10/30/2013	0.002	
LE99673	H S FOUNTAIN	10/30/2013	0	

*** All lead samples will be reviewed by the Local Health Department to determine the 90th percentile value and compliance with lead regulations. Results that are below the detection limit of the analytical method employed by the laboratory are listed as zero.**

For information on reducing lead exposure and the health effects of lead, visit the U.S. EPA's Website at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

Printed: 11/12/2013